

ANNUAL REPORT OF MONITORING

Lac Le Jeune Provincial Park

2011 Operating Season

Section 15 of the *Drinking Water Protection Act* and section 11(b) of the Drinking Water Protection Regulation require annual reporting of monitoring as required by the regulation, operating permit, and the Drinking Water Officer. No specific form is specified; however, the following form may be considered for use by water suppliers as appropriate.

WATER SYSTEM ANNUAL REPORT OF MONITORING
Report of Monitoring under Section 15 of the *Drinking Water Protection Act*

GENERAL INFORMATION

Date of report February 15th 2012

Period of monitoring covered by this report May 15th 2011 to Sept 15th 2011

Water supply system operating permit number 0660586

Location of water supply system Lac Le Jeune Provincial Park

Name of owner(s)¹ B.C.Parks

Name and contact information for person to contact if anyone has questions regarding this report.

James Luton / Brandywine Environmental Management Ltd.

1508 Cascade St. , Kamloops, B.C. V2E 1B9

Phone : 250 – 682 – 6686 or 250 – 374 - 7978

IMPROVEMENT ACTIONS AND PLANS

1. Indicate the steps taken to address circumstances in which monitored parameters exceeded permitted levels and to avoid similar occurrences in the future.

The chlorine dose was increased to correct the high Total Coliform counts in August, probably a result of high temperatures during that period.

2. Indicate improvements or remedial actions that are required by the operating permit or Drinking Water Officer, and the required timelines for such improvements or remedial actions.

The McConnell Lake Hand Pump was shocked in May 2011 and re-shocked in August after cleaning the drain and getting a high Total Coliform count.

3. Indicate any additional plans for improvements, including timelines.

No plans for improvements are pending at this time.

PUBLICATION OF THIS REPORT

Unless directed otherwise by a Drinking Water Officer, this report must be made public in the following manner:

(a) For systems serving fewer than 50 connections:

- By mailing a copy of the report to each user of the system who resides in a building served by the system, along with information about how to contact the water supplier for further information.
- By providing a copy to any municipality and regional district within which the water supply system is located.

(b) For systems serving between 50 and 500 connections:

- By mailing a copy of the report to each user of the system who resides in a building served by the system, along with information about how to contact the water supplier for further information.
- By posting a copy of the report at the main site of the water supply system operations (or alternatively, posting notice of where a copy of the report can be obtained).
- By providing a copy to any municipality and regional district within which the water supply system is located.

(c) For systems serving over 500 connections

- By posting a copy of the report at the main site of the water supply system operations (or alternatively, posting notice of where a copy of the report can be obtained).
- By providing a copy to any municipality and regional district within which the water supply system is located.
- By posting a notice in local newspapers advising that the annual report of monitoring is available for review, and providing information on how a person can obtain a copy of the report.

In addition to the foregoing requirements, water suppliers are encouraged to make the report publicly available through other means, such as posting on internet sites, etc.